


RIGID VINYL SERIES – WALL MOUNTED PATHMARKING DOOR SIGNS

The Rigid Vinyl Series – Wall Mounted Photoluminescent Pathmarking Signs provide visibility and indicate direction of egress in all light conditions. The signs are designed to be installed on the wall beside egress doors with a 3M Foam tape. The photoluminescent signs are visible for many hours after the lights go out, having been charged from sunlight or artificial light.

					
EXIT TO THE RIGHT	EXIT TO THE LEFT	FINAL EXIT TO THE RIGHT	FINAL EXIT TO THE LEFT	EXIT THROUGH LOBBY LEFT	EXIT THROUGH LOBBY RIGHT
RAE2122-G250R	RBE2122-G250R	RAF2128-G250R	RBF2128-G250R	RBY4219-G250R	RAY4219-G250R
8.4" x 8.89" (213.36mm x 226mm)	8.4" x 8.89" (213.36mm x 226mm)	8.4" x 11.1" (213.36mm x 282mm)	8.4" x 11.1" (213.36mm x 282mm)	16.4" x 7.4" (416.56mm x 188mm)	16.4" x 7.4" (416.56mm x 188mm)

INSTALLATION INSTRUCTIONS

- Installs easily with 3M foam tape. Some surface preparation is required to ensure a strong bond.
- The foam tape allows for a strong installation on a variety of surfaces. The rigidity of the product spreads any applied load over a greater area of installation adhesion.

THE ECOGLO RIGID VINYL SERIES – WALL MOUNTED PATHMARKING DOOR SIGNS MEETS THE FOLLOWING BUILDING, FIRE & LIFE SAFETY CODES:

- IBC/IFC (Section 1025 – Luminous Egress Path Markings) and (Section 1025)
- NFPA 101
- NYC Building Code 2018 (Section BC 1025 Luminous Egress Path Markings)
- NYC LL 141 of 2013 (Section BC 1025 Luminous Egress Path Markings)
- NYC LL 26 of 2004 Reference Standard 6-1
- California Building Code Section 1025 Exit Passageways
- Connecticut State Fire Safety Code Section 1026 Floor Proximity Egress Path Markings

BENEFITS AND TECHNICAL DETAILS: Ecoglo Rigid Vinyl Series – Wall Mounted Pathmarking Door Signs meets or exceeds the performance criteria specified in the following tests or standards.

BRIGHTNESS

High visibility in dark or light conditions.

- ASTM E2073-02, Standard Test Method for Photopic Luminance of Photoluminescent (Phosphorescent) Markings.
- ISO 17398:2004 Clause 7.11, Safety Colors and Safety Signs- Classification, Performance and Durability of Safety Signs
- UL 1994 Listed – IMZI.SA3353
- ULC 572 Listed – IMZI7.SA3353

WASHABILITY

Easy Cleaning.

- ASTM D4828-94(2003), Standard Test Methods for Practical Washability of Organic Coatings.

RADIOACTIVITY

No radioactivity or toxicity.

- Toxicity: Bombardier SMP 800-C (2000), Toxic Gas Generation Test.

FLAMMABILITY

Does not burn.

- ASTM E162-02, Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source.



SA33553
4HTD
UL 1994 AND
ULC 572 LISTED



BIMready

CONTACT ECOGLO INC. FOR A QUICK QUOTE OR TO OBTAIN MORE INFORMATION ABOUT OUR EMERGENCY LIGHTING PRODUCTS.

ecoglo[®]
VISIBLY BETTER

888-679-4022

241 Main Street, #100, Buffalo, NY 14203

www.ecoglo.us